



EM  
15/9/22  
Principal



**AQUACHEK**  
THE WATER TESTING FACILITY  
FROM EUREKA FORBES LTD.  
(AN ISO 9001:2015 CERTIFIED LABORATORY)



## TEST REPORT

Report /ULR No : TC8433220000000795F  
Sample Receipt Date : 08.09.2022  
Analysis Date : 08.09.2022 to 13.09.2022  
Date of Report Issue : 13.09.2022  
Customer Ref No / Date: DPS/MRD/Sept -2022

Sample Code No : AWQRC/09/22/795  
Sample Description : Water  
Quantity : 1 litre  
Sample Condition : Satisfactory & Sealed  
Sample Type : Water Sample  
Sample Detail : **Drinking Water.**  
Location : (Ground Floor, Nursery School)

**ISSUED TO:-**  
THE PRINCIPAL  
DELHI PUBLIC SCHOOL  
Mathura Road, Sunder Nagar,  
New Delhi-110003

## TEST RESULTS

PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
Sl No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Turbidity	NTU	BDL(DL=0.1)	1	IS:3025 (Part 10)-1984
2.	pH value	-	7.83	6.5-8.5	IS:3025 (Part 11)-1983
3.	Total Dissolved Solids	mg/l	88	500	IS:3025 (Part 16)-1984
4.	Total Hardness as CaCO <sub>3</sub>	mg/l	44	200	IS:3025 (Part 21)-2009
5.	Free Residual Chlorine	mg/l	BDL(DL=0.2)	0.2	IS:3025 (Part 26)-2021

BDL= Below Detection Limit. DL=Detection Limit.

**Remarks:-**

- The Above water sample **conforms** to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted.
- The results relate to item tested.

24/09

Lab Address :

C-348, 3<sup>rd</sup> Floor, Ramphal Chowk  
Sector 7, Dwarka, New Delhi  
Mob No: 9868911295, 01141608075

Principal  
24/9/22  
DELHI PUBLIC SCHOOL  
Mathura Road  
New Delhi-110003

Authorised Signatory  
**Vikas Bhardwaj**  
Quality Manager

Page 1 of 1

Corporate Office  
B1/B2, 701, Marathon Innova, Off Ganpatrao Kadam Marg,  
Lower Parel, Mumbai - 400013, India  
Phone : +91-22-62601888, 48821700 / 09 / 13

Regd. Office  
7, Chakraberia Road (South)  
Kolkata-700025, India  
Phone : +91-33-24755402